



ATTESTATION

Attestation No. 14-PPA-0000022/01-TIC

WE HEREBY DECLARE THAT THE PHOTOVOLTAIC MODULES WITH THE MODEL

DS72300W
(Tested Type)

And with Types extended for similarity*
- See Annex -

MANUFACTURER & LICENSE HOLDER
DUSOL INDUSTRIES LLC
P O Box 381057, Dubai - United Arab Emirates

IS IN COMPLIANCE WITH THE REQUIREMENTS OF
IEC 61701: 2011 - level of severity 1
Salt mist corrosion testing of photovoltaic (PV) modules

AS RESULT OF THE TEST IN OUR APPOINTED LABORATORY
EA ACCREDITED LABORATORY N. 0951

REPORT No. TIC-AR14TEST092

Expiring date 22.04.2020
(Providing that the testing basis continues unchanged)

Notes: (*) The manufacturer declares that these products are constructed using the same materials, components and processes as the tested type DS72300W. Further details on certified models are reported on the attachment. Technical data, materials and components description are into the indicated test reports. Any changes of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval. The certification is performed on tested model as complete certification. This certificate is for type approval and based on voluntarily product test and without Factory Inspection.



Am Bonner Bogen 2, D-53227 Bonn,



23.04.2015 Ing. K. Lindenblatt
TÜV INTERCERT Certification Body

TÜV INTERCERT GmbH - Group of TÜV Saarland • Am Bonner Bogen 2 • 53227 Bonn GERMANY
www.tuv-intercert.org

ATTESTATION ■ ATTESTATO ■ BESTÄTIGUNG ■ TASDIKNAME ■ ATESTADO ■ گواہینامہ ■ BEE



CERTIFICATE

Certificate No. 14-PPV-0000022/01-TIC

WE HEREBY CERTIFY THAT THE PHOTOVOLTAIC MODULES WITH THE MODEL

DS72300W
(Tested Type)

And with Types extended for similarity*
- See Annex -

MANUFACTURER & LICENSE HOLDER
DUSOL INDUSTRIES LLC
P O Box 381057, Dubai - United Arab Emirates

IS IN COMPLIANCE WITH THE REQUIREMENTS OF
IEC 61215 : 2005
(Crystalline silicon terrestrial photovoltaic (PV) modules – Design qualification and type approval)
&
IEC 61730-1 : 2004 + A1: 2011, IEC 61730-2 : 2004 + A1: 2011()**
(Photovoltaic (PV) module safety qualification)
To be used in plants at a total voltage up to: 1000 Vdc (application Class A)

AS RESULT OF THE TEST IN OUR APPOINTED LABORATORY
EA ACCREDITED LABORATORY N. 0951


REPORT No. TIC-AR14TEST091, TIC-AR15TEST026
TIC-1700.0CI0262/14 Rev.1

Expiring date 22.04.2020
(Providing that the testing basis continues unchanged)

Notes: (*) The manufacturer declares that these products are constructed using the same materials, components and processes as the tested type DS72300W. Further details on certified models are reported on the attachment. Technical data, materials and components description are into the indicated test reports. Any changes of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval. (**)The fire test (IEC 61730-2 / MST 23) was performed. Fire class C is assessed. The certification is performed on tested model as complete certification. This certificate is for type approval and based on voluntarily product test and without Factory Inspection.



Am Bonner Bogen 2, D-53227 Bonn,



23.04.2015 Ing. K. Lindenblatt
TÜV INTERCERT Certification Body

TÜV INTERCERT GmbH - Group of TÜV Saarland • Am Bonner Bogen 2 • 53227 Bonn GERMANY
www.tuv-intercert.org

CERTIFICATE ■ CERTIFICATO ■ ZERTIFIKAT ■ SERTIFIKA ■ CERTIFICADO ■ گواہینامہ ■ ΠΙΣΤΟΠΟΙΗΤΙ